



Product Service

Attestation of Conformity

No. N8A 079563 0069 Rev. 00

Holder of Attestation: **Xiamen Yankon Energetic Lighting Co., Ltd.**

No. 88 Houxiang Road, Haicang District
361026 Xiamen
PEOPLE'S REPUBLIC OF CHINA

Product: **Recessed luminaires
(LED PANEL LIGHT)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64140230102801

Date, 2023-06-21

(Richard Xu)

Page 1 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®



Product Service

Attestation of Conformity

No. N8A 079563 0069 Rev. 00

Model(s):

PLC3G1N-R60X60 36W 33E830B,
 PLC3G1N-R60X60 36W 36E840B,
 PLC3G1N-R60X60 36W 36E865B,
 PLC3G1NU-R60X60 36W 33E830B,
 PLC3G1NU-R60X60 36W 36E840B,
 PLC3G1NU-R60X60 36W 36E865B,
 PLC3G1N-TA-R60X60 36W 33E830B,
 PLC3G1N-TA-R60X60 36W 36E840B,
 PLC3G1N-TA-R60X60 36W 36E865B,
 PLC3G1NU-TA-R60X60 36W 33E830B,
 PLC3G1NU-TA-R60X60 36W 36E840B,
 PLC3G1NU-TA-R60X60 36W 36E865B,
 CODA-MCO-60X60-FW 30M003,
 CODA-MCO-60X60-FW 40M003,
 CODA-MCO-60X60-FW 65M003,
 CODA-MCU-60X60-FW 30K001,
 CODA-MCU-60X60-FW 40K001,
 CODA-MCU-60X60-FW 65K001,
 FPL74600v0-ex+LD247038-C0900,
 FPL74700v0-ex+LD247038-C0900,
 FPL71800v0-ex/ta+LD247038-C0900,
 FPL71900v0-ex/ta+LD247038-C0900

Brand:

YANKON, energetic, MEGAMAN, eco-getic, ceotis



Parameters:

Rated Voltage:	220-240V~
Rated Frequency:	50/60 Hz
Rated Power:	36W
Protection Class:	Class II
Degree of Protection:	IP20 for the parts above the recess / IP40 for the parts beneath the recess
Blue Light Risk Group:	RG0
ta:	40°C

Page 2 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.





Product Service

Attestation of Conformity

No. N8A 079563 0069 Rev. 00

Model list

Model 1	Model 2	Model 3	Rated Power (W)
PLC3G1N-R60X60 36W 33E830B	CODA-MCO-60X60-FW 30M003	FPL74600v0- ex+LD247038-C0900	36
PLC3G1N-R60X60 36W 36E840B	CODA-MCO-60X60-FW 40M003		36
PLC3G1N-R60X60 36W 36E865B	CODA-MCO-60X60-FW 65M003		36
PLC3G1NU-R60X60 36W 33E830B	CODA-MCU-60X60-FW 30K001	FPL74700v0- ex+LD247038-C0900	36
PLC3G1NU-R60X60 36W 36E840B	CODA-MCU-60X60-FW 40K001		36
PLC3G1NU-R60X60 36W 36E865B	CODA-MCU-60X60-FW 65K001		36
PLC3G1N-TA-R60X60 36W 33E830B	--	FPL71800v0- ex/ta+LD247038- C0900	36
PLC3G1N-TA-R60X60 36W 36E840B	--		36
PLC3G1N-TA-R60X60 36W 36E865B	--		36
PLC3G1NU-TA-R60X60 36W 33E830B	--	FPL71900v0- ex/ta+LD247038- C0900	36
PLC3G1NU-TA-R60X60 36W 36E840B	--		36
PLC3G1NU-TA-R60X60 36W 36E865B	--		36

**Tested
according to:**

EN IEC 60598-1:2021/A11:2022
EN 60598-2-2:2012
EN 62493:2015

Page 3 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

